



ComEx Global Portfolio

Tips for making
a correct quote

Guideline and information for ComEx Global Portfolio

Replacement options for actuators and modules in ComEx Control Station

When replacing actuators and modules in ComEx enclosures, it is important to ensure that they are replaced according to the same series, i.e. only components from the same series may be replaced in the old series. This is ensured also after the last time buy date via the spare parts business. When completely replacing old boxes with new ones, these can be done at the same location using the same fixing points.

Old ComEx Series

07-33*1-*; 07-33*3-*; 05-0003-00*; 07-351*-*



New ComEx Series

07-33*2-*; 07-33*4-*; 07-3400-*; 07-352*-*



Mixed combination of modules and actuators in ComEx GRP enclosures not allowed



Example

ComEx Global Control Station



Replacement options for illuminated modules and illuminated lamp modules

For the time being, for combinations with illuminated indicator and illuminated push button modules, it is possible to quote both the old ComEx solution and the new one: this up to 30th April 2024, which is the last time buy date. Mixed combinations are not possible due to technical improvements and design adjustment in the new series.

Old ComEx Series

07-33*1-*; 07-33*3-*; 05-0003-00*; 07-351*-*



New ComEx Series

07-33*2-*; 07-33*4-*; 07-3400-*; 07-352*-*



Mixed combination with old and new ComEx Series



Example

Local control station



Important points to consider with the new ComEx Global series

- Switching modules, potentiometer modules and actuators can be combined across generations in local control stations.
- Mixed combinations for components are not allowed in ComEx GRP boxes.
- Mixed combination are not possible for illuminated indicator and illuminated push button modules due to technical improvements and design adjustment in the new generation.
- Assembly holes for ComEx enclosures are identical.
- New/ old actuators fit in the same hole.
- Switch and potentiometer modules are dimensionally identical.
- Yellow indicator lamp consists of a combination of white lamp module and yellow pilot light actuator.
- New accessories: labelling clip, protective collar and locking device, see actuator datasheet.



Toolkit

Questions and answers

What about the control switch?

- The control switch and the corresponding large position selector with protective collar will be available for the new ComEx Global series from March 2024.
- The position selectors are still in the certification phase and have already passed all tests.
- The article numbers are still being created and will then be added accordingly.

Missing or new accessories?

- There are new accessories such as labelling clips, protective collars and locking devices.
- These can be found in the ComEx Global accessories table or in the data sheet "ComEx Global control and signal device actuators and accessories".

Which modules fit with which actuator attachment?

- You can find the appropriate modules and actuator attachments on our homepage.
- Instructions on which module fits which actuator can be found in the "ComEx Global control and indicating station" data sheet.

Price adjustment for the old ComEx series?

- Initially, a price adjustment for the old ComEx series is not planned.
- From 01.08.2024, the current ComEx portfolio will only be available as a spare parts business. In this context, prices will be increased.

Yellow module for indicator light attachment and illuminated pushbutton?

- The yellow indicator light and illuminated pushbutton consists of a combination of a white indicator light module and the yellow indicator light attachment.

How can the current and new ComEx series combine?

- Switching and potentiometer modules can be flexibly combined with the actuators in local control stations
- The dimensions had to be changed to optimise the illuminated and illuminated pushbutton modules. These only fit together in identical series.
- Further information can be found in the file "Guideline and Information_ComEx_Global.pdf"

Until when can the old series still be ordered?

- The old series can be ordered until 30th April 2024.
- Last delivery will be on 31 July 2024.
- Support will end at the end of 2024

Toolkit

Questions and answers

When is the ComEx Flex junction box available?

- The new junction box for our panel mounting will be available with the ComEx Global series from March 2024.
- The junction box is still in the certification phase

Emergency stop twist-to-release labelling?

- The labelling for the emergency stop twist-to-release without labelling.



- The labelling for the emergency stop twist-to-release with labelling.



Emergency stop pull-to-release labelling?

- The labelling for the emergency stop pull-to-release without labelling.



- The labelling for the emergency stop pull-to-release with labelling.



BARTEC Top Holding GmbH
Max-Eyth-Straße 16
97980 Bad Mergentheim

T +49 7931 597 0
info@bartec.com
www.bartec.com