



中国国家强制性产品认证证书



证书编号：2020322304000806

认证委托人名称：博太科防爆设备（上海）有限公司
认证委托人地址：上海市闵行区浦江高科技园 F 区新骏环路 188 号 7 号楼 101、401
生产者名称：BARTEC GmbH
生产者地址：Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
生产企业名称：BARTEC GmbH
企业地址：Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
产品名称：嵌入式微动开关
系列、规格、型号：07-1501 系列
标准：GB 3836.1-2010、GB 3836.2-2010
上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。
发证日期：2020 年 8 月 26 日 有效期至：2025 年 8 月 25 日
首次发证日期：2020 年 8 月 26 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0000844



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304000806

APPLICANT: BARTEC Explosion Proof Appliances (Shanghai) Co. Ltd
ADDRESS: 101, 401, New Building 7, No. 188, Xinjun Ring Rd., Shanghai
 Pujiang Hi-Tech Park(Pu Dong Area), Minhang
 District, Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCTNAME: Built-In Switch
SERIES, SPECIFICATION, MODEL: 07-1501 Series
STANDARDS: GB 3836.1-2010、GB 3836.2-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: August 26, 2020

Valid until: August 25, 2025

Date of original certification: August 26, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0000488



中国国家强制性产品认证证书



SITIIS
Worldwide Access

证书编号：2020322304000806

附 件

产品名称： 嵌入式微动开关

型号规格： 07-1501- **a b c d**

其中

a 代表嵌入式开关型号和电流，可选代码为 5, 6, 7

b 代表导线长度，可选代码为 0~9

c 代表触点类型，可选代码为 1, 2, 3

d 为与防爆无关代码

防爆标志： Ex d IIC Gb

电气参数： 额定电压 250V，额定电流5A。

批 准：



上海仪器仪表自控系统检验测试所有限公司