



中国国家强制性产品认证证书



证书编号: 2021322304003611

认证委托人名称: 博太科防爆设备(上海)有限公司
认证委托人地址: 上海市闵行区浦江高科技园F区新骏环路188号7号楼101、401
生产者名称: BARTEC GmbH
生产者地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
生产企业名称: BARTEC GmbH
生产企业地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
产品名称: 07-29系列限位开关
系列、规格、型号: 07-29ab-c d e /g h i j
标 准: GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2021年1月5日 有效期至: 2026年1月4日
首次发证日期: 2021年1月5日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2021322304003611

APPLICANT: BARTEC Explosion Proof Appliances (Shanghai) Co., Ltd.
ADDRESS: New Building 7, 101、401 No. 188, Xinjun Ring Road,Pujiang Hi-Tech Park, Minhang District,Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCTNAME: Precision Limit Switch
SERIES,SPECIFICATION,MODEL: 07-29ab-c d e /g h i j
STANDARDS: GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:January 5, 2021

Valid until: January 4, 2026

Date of original certification:January 5, 2021

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:



 Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0004353



中国国家强制性产品认证证书



证书编号: 2021322304003611

附件

产品名称: 07-29系列限位开关

型号规格: 07-29ab-c d e l g h i j

- a 可为 5, 6
- b 可为 1, 3, 4
- c 可为 1~8
- d 可为 0~9
- e 可为 62, 30
- g~j 与防爆无关代码

防爆标志: Ex d IIC T5/T6 Gb, Ex tD A21 IP65 T95°C/T80°C (07-296系列)
 Ex d IIC T6 Gb, Ex tD A21 IP65 T80°C (07-295系列)

电气参数:

产品类型	07-295 系列		07-296 系列	
	AC-15	DC-13	AC-15	DC-13
使用类别	AC-15	DC-13	AC-15	DC-13
额定电压	250V	230V	250V	230V
额定电流	5A	0.16A	6A(T6)/3A(T5)	0.25A

批 准:



上海仪器仪表自控系统检验测试所有限公司