# CESI

CESI Centro Elettrotecnico Sperimentale Italiano Glacinto Motta SpA

Via R. Rubettino 54 20134 Milano - Italia Telefono +39 022125 1 Fax +39 0221255440 www.cesi it

Capitale sociale 8 550 000 € interamente versato Codice fiscale e numero iscrizione CCIAA 00793580150

Registro Imprese di Milano Sezione Ordinaria N. R.E.A. 429222 P.I. IT00793580150



Il CESI è stato autorizzato dal governo Italiano ad operare quale organismo di certificazione di apparecchi e sistemi destinati a essere utilizzati in atmosfera con D.M. 173/1983, D.M. 196/1980, D.M. 2077/1998 e.D.M. 2779/2000

# CERTIFICATE



### (1) EC-TYPE EXAMINATION CERTIFICATE

[2] Equipment or Protective System intended for use in potentially explosive atmospheres

Directive 94/9/EC

[3] EC-Type Examination Certificate number:

#### CESI 02 ATEX 097

[4] Equipment: Command, control and signalling units series CCF... and EJB...

[5] Manufacturer: BARTEC NEDERLAND b. v.

[6] Address: Keurmeesterstraat 17b, Ridderkerk (Netherlands)

[7] This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

[8] CESI, notified body n. 0722 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment or protective system has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report n. EX-A2/031047.

[9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 50014: 1997 +A1...A2 EN 50018:2000

[10] If the sign "X" is placed after the certificate number, it indicates that the equipment or protective system is subject to special conditions for safe use specified in the schedule to this certificate.

[11] This EC-TYPE EXAMINATION CERTIFICATE relates only to the design, examination and tests of the specified equipment or protective system in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

[12] The marking of the equipment or protective system shall include the following:

Ex II 2 G EEx d IIB T6 or T5 or T4

This certificate may only be reproduced in its entirety and without any change, schedule included.

Date October 4th, 2002 Translation issued on October 4th, 2002

Prepared Mirko Balaz

Balox h

Approved Ulisse Colombo

CESI

CENTRO ELETTROTECNICO SPERIMENTALE ITALIANO

Business Unit Certificazione

Win Cololut

Page 1/3

Schedule [13]

#### [14] EC-TYPE EXAMINATION CERTIFICATE n. CESI 02 ATEX 097

#### [15] Description of equipment

Command, control and signalling units series CCF... and EJB...

The enclosures of these units are made in aluminium or in stainless steel (see technical note A4-4105 annexed to this certificate).

The various items of the code indicate the size of the enclosure (from 1 to 6), constructional modifications, the type of material used, the presence of glass windows.

The complete codes of all the units subject of this certificate are reported in the drawing EE.246.1 annexed to this certificate.

The enclosures of the command, control and signalling units are subject of the certificate of component CESI 01 ATEX 004 U. All the constructional details of the enclosures are reported in the drawings annexed to this certificate of component.

The types of electrical and electronic components installed inside the command, control and signalling units are reported in the technical note A4-4105 together with their electrical characteristics.

On the enclosures of the CCF and EJB units, accessories and windows as indicated in the certificate of component CESI 01 ATEX 004 U and command and signalling operators series M... P... as indicated in the certificate of component CESI 02 ATEX 002 U can be installed.

#### Electrical characteristics

Rated voltage

24 + 1000 V a.c.

12 ÷ 250 d.c.

Rated frequency

50 + 60 Hz

....

Max, current in fuses and contacts

400 A

400 A

Ambient temperature

-20 + + 40 °C - 20 ÷ + 55 °C

Maximum lamp power

5 W for ambient temperature - 20 + + 40 °C 3 W for ambient temperature - 20 + + 55 °C

Temperature class

T6, T5, T4 as a function of the enclosure dimension, ambient temperature and power dissipated inside the

enclosure

Maximum values of the power which can be dissipated inside the enclosure CCFE-6 having the maximum volume

Ambient temperature	+ 40 °C			+55 °C		
Temperature class	T6	T5	T4	T6	T5	T4
Dissipated power [W]	600	910	1740	460	680	1300

The maximum power which can be dissipated inside the enclosure and the maximum current on contacts and fuses are a function of enclosure size, of the temperature class and of the ambient temperature as specified in details in the documentation annexed to this certificate.

This certificate may only be reproduced in its entirety and without any change, schedule included.



P: 3

48010M 542500

66540E

[13] Schedule

### [14] EC-TYPE EXAMINATION CERTIFICATE n. CESI 02 ATEX 097

#### [15] Description of equipment (follows)

The accessories used for cable entry and for closing unused apertures shall be certified according to the standards EN 50014 and EN 50018.

The service temperature of windows and of signal and control operators series M... P... shall not exceed 100 °C.

#### Warning label

"Use screws of quality A2-70 according UNI 7323 with ultimate tensile strength of at least 700 N/mm2".

#### Additional warnings

In case of enclosures including capacitors:

"After de-energizing, wait 10 minutes before opening"

In case of enclosures of temperature class T4 or T5:

"Use cables suitable for a temperature of 100 °C:

#### [16] Report n. EX-A2/031047

#### Routine tests

The manufacturer shall carry out the routine tests prescribed at clause 24 of the EN 50014 standard.

The routine overpressure test shall be carried out with the static method (clause 15.1.3.1 of EN 50018 standard) at the pressure of:

- 11.9 bar for enclosure size from 1 to 5
- 11.5 bar for enclosure size 6

#### Descriptive documents (prot. EX-A2/031048)

- n. A4-4105 Rev. 0 (2 p.)	dated	11.03.2002
- n. EE.246.1 Rev. 0	dated	11.03.2002
- n. A4-4129 Rev. 0	dated	11.03.2002
- Safety instructions SAFETY EJB Rev. 0 (5 p.)	dated	11.03.2002
- EC declaration of conformity	dated	11.03.2002
One copy of all documents is kept in CESI files.		

## [17] Special conditions for safe use

None.

#### [18] Essential Health and Safety Requirements

Covered by standards.

