

Customer \_\_\_\_\_

Commission number \_\_\_\_\_

Project \_\_\_\_\_

Building \_\_\_\_\_

Item	Installed cable length in metres	Measured insulation resistance in MΩ between conductors 1 and 3 before installation	Measured insulation resistance in MΩ between conductors 1 and 3 after installation*	Measured insulation resistance in MΩ between conductor 1 to ground conductor 3 to ground**		Volume resistance in Ω between conductors 1 and 2 conductors 3 and 4*		Calculated volume resistance in Ω/m **	Date of test/ test engineer
				conductor 1	conductor 3	conductor 1 and 2	conductor 3 and 4		
1									
2									
3									
4									

\* (measured with end plug), measurement section: sensor cable with incoming feed line

\*\* (measured resistance of conductors 1 and 3 in Ω/installed cable length = calculated resistance in Ω/m)

Conductor 1 = contact 1 = wire white with perforation

Conductor 2 = contact 2 = wire white insulated

Conductor 3 = contact 3 = wire red with perforation

Conductor 4 = contact 4 = wire red insulated

**Note**

The sensor cable must be checked during assembly also. When checking, disconnect the sensor cable from the monitoring electronics.

**Test tolerance for the measurements**

Volume resistance in Ω: min: 5.7 Ω/m, max: 6.3 Ω/m

Insulation resistance in MΩ: not less than 10 MΩ per entire measuring circuit (at a test voltage of 500 V)

\_\_\_\_\_  
Stamp/signature of installation company

All warranty claims are subject to the submission of a correctly and completely filled-in acceptance report. Date and signature are also required.